

EXHAUST FAN SCHEDULE (SEE Es for location in a given space):

| SITE | SPACE | NUTONE | CFM | SONES | WATTS | DUCT |
|------------|----------------------|--------|-----|-------|-------|-------------|
| House, L1 | Master Bath, Bog | LS80L | 80 | 0.8 | 100 | 4" diameter |
| House, L1 | Master Bath, Non-bog | QT200 | 200 | 2.0 | --- | 3 1/4"x10" |
| House L1 | 1/2-Bath | LS80L | 80 | 0.8 | 100 | 4" diameter |
| House, L1 | Guest Bath | QT200 | 200 | 2.0 | --- | 3 1/4"x10" |
| House, L1 | Utility | QT200 | 200 | 2.0 | --- | 3 1/4"x10" |
| House, L2 | Bath 2 | QT200 | 200 | 2.0 | --- | 3 1/4"x10" |
| House, L2 | Bath 3 | QT140L | 140 | 2.0 | 100 | 3 1/4"x10" |
| House, L2 | Bath 4 | LS100L | 110 | 1.5 | 100 | 4" diameter |
| Garage, L1 | 1/2-Bath | LS80L | 80 | 0.8 | 100 | 4" diameter |

See S12A.8.